

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing A.B.N 43 006 014 106 1st Floor, 191 Racecourse Road, Flemington, Victoria 3031 P.O Box 240, North Melbourne, Victoria 3051 Phone (03) 9371 2400 Fax (03) 9371 2499

TEST REPORT

Client :	The Shann Group 1/73 Gower Street		Test Number Issue Date	: 23/08/20	19	
	Preston VIC	3072	Print Date Order Numbe		2/09/2019 MVTRPVC	
Sample D	Description	Clients Ref : "TENTROOF" Woven coated PVC fabric Colour : White End Use : Various - general co Nominal Composition : Coate Nominal Mass per Unit Area/Der	ed Polyester			
AS 1530.2-19	93	Methods for Fire Tests on Build Part 2: Test for Flammability of		ents and Structu	res.	
		Date Tested			22/08/2019	
		Flammability Index			1	
		-		Length	Width	
		Spread Factor		0	0	
		Heat Factor		1	1	
		Maximum height (d)				
		Mean		2.1	1.9	
		Coefficient of Variation		9.8	10.6	%
		Heat (a)				
		Mean		1.5	1.5	°C.min
		Coefficient of Variation		0.0	0.0	%
		Number of Specimens Tested		6	6	
		Observation	Visible smoke, melting.			

These test results relate only to the behaviour of the test specimens of the material under the particular conditions of the test, and they are not intended to be the sole criterion for assessing the potential fire hazard of the material in use.

178538 38293 Page 1 of 1 Australian Wool testing Authority Ltd Copyright - All Rights Reserved Accredited for compliance with ISO/IEC 17025 - Testing : Accreditation No 983 - Chemical Testing Mechanical Testing : Accreditation No 985 Performance & Approvals Testing : Accreditation No 1356 Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by the Managing Director of AWTA Ltd.

APPROVED SIGNATORY



(C)

A